



丹尼食品有限公司
DANNY CATERING SERVICE LTD.

香港新界葵涌貨櫃碼頭路77-81號 大鴻輝(葵涌)中心第一期3樓
3/F., Prosperity Centre, 77-81 Container Port Road, Kwai Chung, New Territories, Hong Kong
TEL (852) 2759 8251 **FAX** (852) 2759 8917



有關:中央生產廠房水質化驗報告

致午膳負責人:

鑑於近日本港受到鉛水事件之影響，引起部分人士的不安，我司表示極度關注，為釋除各方疑慮，我司已於八月二十八日安排本港認可之第三方化驗所 CHEMLAB 派員到我司位於葵涌的中央生產廠房，抽取食水樣本作化驗，而化驗之內容包括了七種重金屬之元素:鉛、鎘、砷、鎳、鉻、汞及鎳，結果顯示全部均符合世界衛生組織之標準。

現隨函附上詳細之化驗報告供校方參考，如對以上內容有任何疑問，歡迎致電負責貴校之區域主任/經理，或致電我司客戶服務熱線 2759 8251 查詢，謝謝!

順祝

校務蒸蒸日上



丹尼食品有限公司
銷售及市場部
二零一五年九月八日

Test Report

Company Name: Danny Catering Services Ltd
 Company Address: Room 307-308, 3/F, Prosperity Centre,
 77-81 Container Port Road,
 Kwai Chung, N.T.

Test Report No.: HK/WT/0809/15/08
 Date of Issue: 8th Sep 2015
 Page : 1 of 1

Sample Description 樣品描述 : One (1) bottle of Water Sample (水辦)
 Sample Condition 樣品取樣時狀態 : In closed plastic bottle, under chilled condition during delivery
 Production Date 製造日期 : 28/8/2015
 Date Sample Received 樣品收取日期 : 28th Aug 2015
 Period Analyzed 檢測日期 : 28th Aug 2015 – 4th Sep 2015

Chemical Analysis - Heavy Metals 化學分析 - 重金屬

Parameter(S) 參數	Unit 單位	Result 結果	Test Method 檢測方法
Antimony (Sb) 錒	mg / L	ND (< 0.0002)	Standard Methods of the Examination of Water and Wastewater, 21 st Edition, by APHA, part 3500-As, 3500-Cd, 3500-Cr, 3500-Pb, 3500-Hg, by Inductively Coupled Plasma Mass Spectrometry analysis
Arsenic (As) 砷	mg / L	ND (< 0.0002)	
• Cadmium (Cd) 鎘	mg / L	ND (< 0.002)	
• Chromium (Cr) 鉻	mg / L	ND (< 0.01)	
• Lead (Pb) 鉛	mg / L	ND (< 0.002)	
Mercury (Hg) 汞	mg / L	ND (< 0.0002)	
Nickel (Ni) 鎳	mg / L	0.0062	

The above results are based solely on the sample(s) sampled by the Laboratory
 Sampling method according to Environment Agency "The Microbiology of Drinking Water" (2010) Part 2
 Results relate only to the items tested

The above tests are subcontracted to a local accredited laboratory, the test parameters marked with • are accredited. Report reference No.: HKGH01855295
 mg / L = milligram per Liter
 ND (< 0.002) = Not Detected (Detection limit is less than 0.002)



Wu Tien Chih
 Microbiologist

-End of Report-

Room 2001-2, 20/F, Trendy Centre,
 682-684 Castle Peak Road, Lai Chi Kok,
 Kowloon, Hong Kong
 Tel: (852) 2606 7178
 Fax: (852) 2310 2990

Information Page

Company Name: Danny Catering Services Ltd
 Sample Description: One (1) bottle of Water Sample (水辦)

Reference Report No.: HK/WT/0809/15/08
 Date of Issue: 8th Sep 2015
 Page : 1 of 1

Conclusion

With reference to World Health Organization (WHO), Guidelines for Drinking-water Quality.
 The test results of submitted sample are summarized as below:

Parameter (s)	Result (s)	Acceptance Limit
Antimony (Sb)	Pass	≤ 0.02 mg /L
Arsenic (As)	Pass	≤ 0.01 mg /L
• Cadmium (Cd)	Pass	≤ 0.003 mg /L
• Chromium (Cr)	Pass	≤ 0.05 mg /L
• Lead (Pb)	Pass	≤ 0.01 mg /L
Mercury (Hg)	Pass	≤ 0.006 mg /L
Nickel (Ni)	Pass	≤ 0.07 mg /L

\leq = Less than or equal to

The above tests are subcontracted to a local accredited laboratory. the test parameters marked with • are accredited. Report reference No : HKGH01855295

Notes:

The above Abstract/Conclusion expressed herein are additional information, reference from the results of the corresponding test report result only.